02/02/2023

Ashley Vander Meiden
701 N A ST
Oskaloosa, IA 52577

Dear Child Care Provider:

This letter is in regards to the pre-inspection visit at your residence in which you are seeking child development home registration conducted on 12/13/2022. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. You are not a participant in the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.7	**Provider Requirements**
441 IAC 110.8	Standards. Conditions in the home are safe, sanitary, and free of hazards.
441 IAC 110.8(1)	**Facility Requirements**
441 IAC 110.8(1)"a"	The home shall have a nonpay, working land-line or mobile telephone with emergency numbers posted for police, fire, ambulance, and the poison information center. The number for each child's parent, for a responsible person who can be reached when the parent cannot, and for the child's physician shall be written on paper and readily accessible by the telephone. The home must prominently display all emergency information, and all travel vehicles must have a paper copy of emergency parent contact information
441 IAC 110.8(1)"g"	The home shall have at least one 2A 10BC rated fire extinguisher located in a visible and readily accessible place on each child-occupied floor.
441 IAC 110.8(1)"h"	The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer's recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes
441 IAC 110.8(1)"i"	Smoking and the use of tobacco products shall be prohibited at all times in the home and in every vehicle in which children receiving care in the home are transported. Smoking and the use of tobacco products shall be prohibited in the outdoor play area during the home's hours of operation. Nonsmoking signs shall be posted at every entrance of the child care home and in every vehicle used to transport children. All signs shall include: **1.** The telephone number for reporting complaints, and **2.** The Internet address of the department of public health (www.iowasmokefreeair.gov)

441 IAC 110.8(4) **Emergency Plans**

441 IAC 110.8(4) Emergency Plans: plans in case of man-made or natural disaster shall be written and posted by the primary and secondary exits. The plans shall clearly map building evacuation routes and tornado and flood shelter areas.

Findings:

1. 110.8 Provider needs to add a railing to one side of the steep entrance stairs to the daycare. (Provider texted a photo on 1/12/2023, showing this was completed).

2. 110.8(1)g Provider has a 1A 10BC fire extinguisher, provider needs to have a 2A 10BC. (Provider texted a photo on 12/15/2022, showing a new, 2A 10BC fire extinguisher).

3. 110.8(1)a Provider needs emergency numbers for Police, Fire, Ambulance and Poison Control posted. (Provider texted a photo on 12/15/2022, showing that she has these emergency numbers posted.)

4. 110.8(1)h Provider needs to add one smoke detector to the living room area. (Provider texted a photo of a smoke detector hanging in the living room on 12/15/2022).

5. 110.8(1)i Provider needs to have No Smoking Signs at all entrances to the daycare home. SW Bailey provided them to provider at the time of the compliance visit.

6. 110.8(4)a Provider needs to hang up a map of evacuations routes/safe places posted at primary and secondary exits. (Provider texted a photo of the map posted at both exits.)

Suggestions/Recommendations:

Corrective Action Required:

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 319-800-4702 or hbailey@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Holly Bailey

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).