01/29/2024

Harmony Young DBA Harmonys Youngsters
2914 E AVE NE
Cedar Rapids, IA 52402

Dear Child Care Provider:

This letter is in regards to the pre-inspection visit at your Registered Child Development Home B conducted on 01/05/2024. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. You are not a participant in the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1) **Facility Requirements**

441 IAC 110.8(1)"b" Electrical wiring shall be maintained, and all accessible electrical outlets shall be tamper-resistant outlets or shall be safely capped. Electrical cords shall be properly used. Improper use includes running cords under rugs, over hooks, through door openings, or other use that has been known to be hazardous

441 IAC 110.8(1)"h" The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer's recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

441 IAC 110.8(3) **Medications and Hazardous Materials**

441 IAC 110.8(3)"a" All medicines and poisonous, toxic, or otherwise unsafe materials shall be secured from access by a child

441 IAC 110.8(4) **Emergency Plans**

441 IAC 110.8(4) "b" The provider must have procedures in place for the following:

1. evacuation to safely leave the facility
2. relocation to a common, safe location after the evacuation
3. shelter-in-place to take immediate shelter where you are when it is unsafe to leave that location due to the emergent issue
4. lock down protocol to protect children and providers from an external situation
5. communication plan and plans for reunification with families
6. continuity of operations plans
7. Procedures to address the needs of individual children, including those with functional or access needs

Findings:

A Pre-Inspection compliance check was completed on 1/5/24 in regards to your change of address and change to Category B provider.
The following was out of compliance on that date:

441 IAC 110.8(1)“b” All accessible electrical outlets shall be tamper-resistant outlets or shall be safely capped.
She had a few not capped but did cap them while this worker was present.

441 IAC 110.8(1)“h” The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway.
She needed one in the kitchen.

441 IAC 110.8(3)“a” All medicines and poisonous, toxic, or otherwise unsafe materials shall be secured from access by a child.
The kitchen cabinet had chemicals that were not secured from the children.

441 IAC 110.8(4) “b” The provider must have procedures in place for the following:
evacuation to safely leave the facility
relocation to a common, safe location after the evacuation
shelter-in-place to take immediate shelter where you are when it is unsafe to leave that location due to the emergent issue
lock down protocol to protect children and providers from an external situation
communication plan and plans for reunification with families
continuity of operations plans
Procedures to address the needs of individual children, including those with functional or access needs
Harmony needed to update this with the recent move.

Suggestions/Recommendations:

Corrections need to be made before the Pre-Inspection on the new address can be approved.

Corrective Action Required:

Harmony did have a few outlets not capped but did cap them while this worker was present on 1/5/24.

Harmony needed to install a smoke detector in the kitchen. She did do this and sent pictorial verification on 1/15/24.

Harmony needed to move chemicals under the kitchen sink or secure them accordingly. She did send pictorial verification of this on 1/15/24.

Harmony needed to update her emergency preparedness plan. She did send pictorial verification of this on 1/29/24.

AS of 1/29/24 the PI is approved with all the necessary items completed.

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 319-429-0749 or cweber@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Christine Weber

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).