10/24/2023

Tabitha Donaldson
2922 Magnolia DR
Bettendorf, IA 52722

Dear Child Care Provider:

This letter is in regards to the compliance visit at your Registered Child Development Home B conducted on 10/24/2023. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. You are not a participant in the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1) **Facility Requirements**

441 IAC 110.8(1)" a" The home shall have a nonpay, working land-line or mobile telephone with emergency numbers posted for police, fire, ambulance, and the poison information center. The number for each child's parent, for a responsible person who can be reached when the parent cannot, and for the child's physician shall be written on paper and readily accessible by the telephone. The home must prominently display all emergency information, and all travel vehicles must have a paper copy of emergency parent contact information

441 IAC 110.9 Files

441 IAC 110.9(1) **A provider file is maintained and shall contain the following:**

441 IAC 110.9(2) An individual file is maintained for each staff assistant and contains:

1. Documentation from the department confirming the record checks required under subrule 110.11(3) have been completed and authorizing or conditionally limiting the person's involvement with child care
2. A completed Form 470-5152, Child Care Provider Physical Examination Report. The examination shall include any necessary testing for communicable diseases; a discussion of recommended vaccinations; completed no more than six months prior to approval to assist or be a household member; completed by a licensed medical doctor, doctor of osteopathy, physician assistant or advanced registered nurse practitioner; and repeated at least every three years.
3. Certification of two hours of approved training related to identification and reporting of child abuse as required by Iowa Code section 232.69 within 3 months of employment.

441 IAC 110.9(3) An individual file is maintained for each substitute and contains:

1. Documentation from the department confirming the record checks required under 441 IAC 110.9(1) "a" have been completed and authorizing or conditionally limiting the person's involvement with child care.
2. A completed Form 470-5152, Child Care Provider Physical Examination Report. The

examination shall include any necessary testing for communicable diseases; a discussion of recommended vaccinations; completed no more than six months prior to approval to assist or be a household member; completed by a licensed medical doctor, doctor of osteopathy, physician assistant or advanced registered nurse practitioner; and repeated at least every three years.

3. Certification of two hours of approved training related to identification and reporting of child abuse as required by Iowa Code section 232.69 within 3 months of employment.
4. Certification in infant and child first aid
5. Certification or other documentation that minimum health and safety training has been completed within 3 months or prior to providing substitute care, whichever occurs first.

441 IAC 110.14(3) **Facility requirements**

441 IAC 110.14(3)"c" The home shall have a minimum of two direct exits to the outside from the main floor.

1. If the second level or the basement of the home is used for the provision of child care, other than the use of a restroom, each additional child-occupied floor shall have at least one direct exit to the outside in addition to one inside stairway.
2. All exits shall terminate at grade level with permanent steps.
3. A basement window may be used as an exit if the window can be opened from the inside without the use of tools and it provides a clear opening of not less than 20 inches in width, 24 inches in height, and 5.7 square feet in area. The bottom of the opening shall be not more than 44 inches above the floor, with permanent steps inside leading up to the window
4. Occupancy above the second floor shall not be permitted for child care.

Findings:

441 IAC 110.8(1)a. Number for each child's parent, a person who can be reached when the parent cannot and child's physician is written on paper and readily accessible by the working telephone.
441 IAC 110.9(2)a. Assistants. Documentation from the Department confirming record checks have been completed and authorizing or limiting the person's involvement with child care.
441 IAC 110.9(3)a. Substitutes. Documentation from the Department confirming record checks have been completed and authorizing or limiting the person's involvement with child care.
441 IAC 110.14(3)c. Egress window. The bottom of the window opening is not more than 44 inches above the floor with permanent steps inside leading up to the window.

Suggestions/Recommendations:

Tabitha needs to update her posted emergency numbers for all enrolled children.
Tabitha needs the completed background check letter for her assistant and substitute. This worker will request and send to Tabitha.
Tabitha's egress window is more than 44 inches from the ground and therefore can not be used for a secondary exit from the basement. Tabitha needs to contact the CCA Unit at 866-448-4605 and request that she change back to a category A provider.

Corrective Action Required:

A follow up visit will not be needed. Tabitha will complete the above items by 12/12/2023.

I encourage you to work with Child Care Resource and Referral for ongoing child care needs.
Lori Mueller
Child Care Consultant
Child Care Resource & Referral of Southeast Iowa
Community Action of Eastern Iowa
lomueller@caeiowa.org
T: 563-362-8226
500 E 59th St.| Davenport, IA 52807| www.iowaccrr.org

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 563-949-6971 or khuinke@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Kathy Huinker

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).