04/28/2023

Kelsey Williams
110 Vine ST
Council Bluffs, IA 51503

Dear Child Care Provider:

This letter is in regards to the pre-inspection visit at your Registered Child Development Home B conducted on 04/28/2023. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. Your home is rated a 1 on the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1)	**Facility Requirements**
441 IAC 110.8(1)“ g”	The home shall have at least one 2A 10BC rated fire extinguisher located in a visible and readily accessible place on each child-occupied floor.
441 IAC 110.8(1)“ h”	The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer’s recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

Findings:

441 IAC 110.8(1)“g” The home shall have at least one 2A 10BC rated fire extinguisher located in a visible and readily accessible place on each child-occupied floor.

**Provider did not have the 2A 10 BC on the main level of the home. She reported it may be in her attic.

441 IAC 110.8(1)“h” The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer’s recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

**Provider is in need of a smoke detector at the top of the stairway going to the attic of the home. She also needs to replace two detectors that are not in the holders. Provider reported just changing batteries and they are not put up just yet.

Suggestions/Recommendations:

Pictures of the fire extinguisher and the smoke detectors can be sent via text to 712-435-0576. Once these are sent, your approval will be sent to registration.

Corrective Action Required:

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 712-435-0576 sburris@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Stacy Burris

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).