IOWA HHS
Iowa Department of Health And Human Services

Kim Reynolds
Governor

Adam Gregg
Lt. Governor

Kelly K. Garcia
Director

05/01/2025

Kathleen Swenka
2692 240th ST NW
North Liberty, IA 52317

Dear Child Care Provider:

This letter is in regards to the compliance visit at your Registered Child Development Home C conducted on 04/30/2025. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. You are not a participant in the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1)	**Facility Requirements**
441 IAC 110.8(1)"h"	The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer's recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes
441 IAC 110.9	Files
441 IAC 110.9(1)	**A provider file is maintained and shall contain the following:**
441 IAC 110.9(1)"a"	A physician's examination report for the provider and all members of the provider's household aged 18 years or older. Acceptable physical examinations shall be documented on Form 470-5152, Child Care Provider Physical Examination Report. All children residing in the household must have medical documentation outlined in 110.9(4) "d", 110.9(4) "f", and 110.9(4) "g"

Findings:

1. 110.8(1)h The provider does not check her smoke detectors monthly, she says she does it every other month or so.

2. 110.9(1) Provider file:
   -The provider does not have a current physical for her husband, in the provider file.

Suggestions/Recommendations:

A re-check is not needed at this time, corrections need to be made by 5/30/25 and will be reviewed at the next annual compliance check.

I encourage you to work with Lorri Hora from Child Care Resource and Referral with any ongoing compliance or training needs.

Lorri can be reached at: 319-321-2725.

Corrective Action Required:

1. The provider needs to test all smoke detectors monthly and keep documentation.

2. The provider needs a current physical for her husband, in the provider file.

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 319-800-4702 or holly.bailey@hhs.iowa.gov if you have any questions regarding this letter.

Sincerely,

Holly Bailey

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).