10/09/2023

Maria Jacinto
1710 Carpenter AVE
Des Moines, IA 50314

Dear Child Care Provider:

This letter is in regards to the compliance visit at your Registered Child Development Home A conducted on 10/09/2023. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. You are not a participant in the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1)	**Facility Requirements**
441 IAC 110.8(1)"h"	The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer's recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

Findings:

441 IAC 110.8(1)"h" The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer's recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

Suggestions/Recommendations:

Each room occupied by child care children need to have smoke detector installed. Your front room where the children spend time needs to have a smoke detector installed.

Corrective Action Required:

A re-check is not needed a this time. The above correction needs to be completed by 12/9/2023 and will be reviewed on your next annual compliance check.

I encourage you to work with your Child Care Resource and Referral Worker (Roxana Sixtos 515-202-1310) to make the above corrections and any other compliance or training efforts.

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 515-601-9469/jaringd@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Jake Aringdale

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: https://ccmis.dhs.state.ia.us/trainingregistry/

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).